

**COMMUNITY REDEVELOPMENT AGENCY
BOARD OF DIRECTORS**

APRIL 15, 2013
MONDAY, 6:30 P.M.
COUNCIL CHAMBERS

THIS MEETING WILL BE HELD AT THE END OF THE
REGULAR CITY COUNCIL MEETING

- A. Discussion and Action Regarding Repair of Storm Water Inlet, Intersection of Soundview Trail and Harbourtown Entrance

If any person decides to appeal any decisions made with respect to any matter considered at this meeting or public hearing, such person may need to insure that a verbatim record of the proceedings is made, which record includes the testimony and any evidence upon which the appeal is to be based.

The public is invited to comment on matters before the City Council upon seeking and receiving the recognition from the Chair.



City of Gulf Breeze

DATE: April 3, 2013

TO: Edwin A. Eddy, City Manager

FROM: Vernon L. Prather, Director of Public Services *V.P.*

RE: Replace Storm Water Inlet Located at
Intersection of Soundview Trail & Harbor Town Entrance

The above referenced storm water inlet is in need of major repair as it is showing visible signs of deformation and potential collapse. The structure appears to be frequently run over by large trucks navigating the corner. In addition, the current design is insufficient for traffic loading of any type. The attached photo illustrates the actual condition of the structure.

Staff developed a scope of work to repair the structure and bring it up to standard will require the removal of the entire top and possible reworking of the brick sub-structure if it has been damaged. A completely new top will be poured along with reinforcement steel and pillars will be added to support the inlet side of the structure.

We also have the ability to coordinate the sidewalk repair and storm water inlet to save costs and disruption activity by using the same contractor for both jobs. This work needs to be performed by a qualified contractor capable of providing the desired scope of work.

There are a several unknown variables for repairing the structure, so staff obtained a not-to-exceed cost of \$4,800 from Utility Service Company.

Since this structure is located in the CRA District, funds could be assigned to repair the storm water structure.

RECOMMENDATION: City Council meet as Community Redevelopment Agency on April 15, 2013 and authorize Utility Service Company to repair the storm water inlet structure at a not-to-exceed cost of \$4,800.

